



Premises Management Policy

Signed by
Chair of
Governors

Agreed by the Board December 2020, next review December 2021



Contents

1. Aims	2
2. Guidance	2
3. Roles and responsibilities	2
4. Inspection and testing	2
5. Risk assessments and other checks	6
6. Monitoring arrangements	6
7. Links with other policies	6

1. Aims

Our school aims to ensure that it:

- Manages its buildings and equipment in an efficient, legally compliant way
- Inspects and tests buildings and equipment regularly, taking into account statutory requirements and best practice recommendations
- Promotes the safety and wellbeing of our staff, pupils, parents and visitors through effective maintenance of buildings and equipment in accordance with the [Health and Safety at Work etc. Act 1974](#)
- Complies with the requirements of [The Education \(Independent School Standards\) Regulations 2014](#)

2. Guidance

This document is based on the Department for Education's guidance on [good estate management for schools](#).

This policy complies with our funding agreement and articles of association.

3. Roles and responsibilities

The governing body, headteacher and site manager will ensure this premises management policy is properly implemented, and that tests and inspections are carried out in accordance with this policy.

The Director of Business Services DoBS and site manager are responsible for ensuring relevant risk assessments are conducted and for reporting to the governing body, as required.

The site manager is responsible for:

- Inspecting and maintaining the school premises
- Conducting repairs and maintenance
- Being the first point of contact for any issues with the premises
- Conducting and keeping a record of risk assessments and incident logs related to the school premises
- Liaising with the DoBS about what actions need to be taken to keep the school premises safe

The Head of the PE department will be responsible for the PE equipment checks.

The Head of Science and DT will be responsible for chemical checks under COSHH requirements.

4. Inspection and testing

We maintain accurate records and details of all statutory tests which are undertaken at our premises. This includes relevant paperwork and certificates.

All requirements and recommendations highlighted in inspection reports and certificates are reviewed and acted on as necessary.

As part of the records of completed works, we include the dates when the works were undertaken and the details of the individual or company who completed them, along with their qualifications/certifications and/or experience.

The table below sets out the issues we inspect, the inspection frequency, and the person responsible for checking each issue and, where appropriate, engaging a suitably qualified person to carry out inspection, testing or maintenance. It covers statutory checks as well as recommended good practice checks from relevant guidance. It is based on the [checks and testing sections of the DfE estates guidance](#).

ISSUE TO INSPECT	FREQUENCY	PERSON RESPONSIBLE
Portable appliance testing (PAT)	Variable, according to risk and how the equipment is constructed. Regular visual inspections where PAT is not required. We will refer to HSE guidance on maintaining portable electric equipment for suggested intervals and types of testing/inspection.	Site Manager – Electech carry out the test every two years.
Fixed electrical installation tests (including lightning conductors)	Variable, according to the number and severity of faults found at last inspection. Inspection and testing always carried out by a competent person.	Site Manager – Electech carry out the test every five years.
Emergency lighting	Monthly flash test. 6-monthly condition test (including 3-hour battery test) by a competent person.	Site Manager – Electech carry out the test every month.
Lifts	At least every 6 months for passenger lifts and lift accessories, every 12 months for other lifts (e.g. goods lifts) – always by a competent person.	Site Manager – OTIS carry this check quarterly.
Gas appliances and fittings	Routinely, in accordance with manufacturer recommendations (or other professional advice if unavailable). Annual safety checks (in line with good practice / required if the premises are used for residential accommodation). All work carried out by a Gas Safe Registered engineer.	Site Manager – GAP Pipe installations check annually.
Air conditioning systems	Inspections by an energy assessor at regular intervals (not exceeding 5 years). Annual certificated inspection to ensure no refrigerant leakage. Bi-annual checks and an annual maintenance schedule (in line with good practice).	Site Manager – OAS 1 major service 1 interim service per annum.

ISSUE TO INSPECT	FREQUENCY	PERSON RESPONSIBLE
Pressure systems	No fixed maintenance requirement (our programme takes account of the list on page 44 of the HSE's Safety of Pressure Systems guidance , and an examination of the system is carried out by a competent person by the date set at the previous examination – see pages 35 to 37 of the HSE guidance).	Our science departments have these checked.
Legionella checks on all water systems	Risk assessment of each site carried out and reviewed regularly by a competent person. The frequency of monitoring checks varies for evaporative cooling systems, hot and cold water systems and other risk systems – specific details can be found in guidance for each type from the HSE .	Site Manager –Green Contract Services every two years and random monthly checks.
Asbestos	Regular inspections as part of the asbestos register and management plan. Reviews of the asbestos register annually. Refurbishment and demolition surveys before any refurbishment or demolition work.	Site Manager – AEC Annual check our school is very low risk.
Equipment used for working at height	Inspected before use, and at suitable intervals appropriate to the environment it's used in and how it's used. In addition, inspections after anything that may affect the safety or stability of equipment, e.g. adverse weather or accidental damage.	Site Manager inspects annually and when needed.
Fire detection and alarm systems	Weekly alarm tests, with a different call point tested each week where applicable. Quarterly and annual inspections and tests by a competent person. Annual fire risk assessment by a competent person also includes the maintenance of fire detection and alarm systems.	Site Team
Fire doors	Regular checks by a competent person.	Site Team

ISSUE TO INSPECT	FREQUENCY	PERSON RESPONSIBLE
Firefighting equipment	Most equipment – extinguishers, fire blankets, hose reels, fixed systems (such as sprinkler systems) and fire service facilities (such as dry risers and access for emergency vehicles) – inspected annually (by a competent person where required) unless manufacturers' guidelines suggest differently.	Site Manager weekly checks – Walker Fire check annually.
Extraction systems	Regular removal and cleaning of grease filters and cleaning of ductwork for kitchen extraction systems. Local exhaust ventilation systems (such as those for working with hazardous substances) examined and tested at least every 14 months by a competent person. More routine checks also set out in system logbooks.	Sodexo – Clearwater check annually
Chemical storage	Inventories are kept up-to-date. Risk assessments for the Control of Substances Hazardous to Health (COSHH) are reviewed on a regular basis, plus whenever it's considered that the original assessment may no longer be valid, or where the circumstances of the work change significantly and may affect employees' exposure to a hazardous substance (in line with HSE guidance on COSHH assessment).	This is handled by our Science Technician, Site Manager & Head of DT
Gymnasium equipment	Regular inspections – at least annually, and more regularly where any equipment is used more frequently than normal (e.g. where community use increases how often equipment is used). Outdoor fixed play equipment – periodic and annual inspections by a competent person.	Head of PE
Tree safety	As part of risk assessment responsibilities, periodic visual checks for stability are carried out, with more detailed assessments if suspected structural faults or other risks are found.	Site Team – Monthly check and as and when needed Tree risk assessment every 5 years

ISSUE TO INSPECT	FREQUENCY	PERSON RESPONSIBLE
Radon	<p>Risk assessments including radon measurements will be carried out in all of our above-ground workplaces in radon-affected areas, and all of our below-ground workplaces.</p> <p>Radon measurements will last for 3 months, using radon monitors, in line with Public Health England radon guidance for schools.</p> <p>Where measurements show radon levels below 300Bq/m³, radon levels will be remeasured at least every 10 years. If significant changes are made to the buildings or work processes, remeasurement will also be considered.</p> <p>For any sites with radon levels above 300Bq/m³ we will work with a radiation protection adviser to manage reduction and decide on risk assessment and remeasurement frequency.</p>	

5. Risk assessments and other checks

Please refer to our risk assessment policy for information about the school's approach to risk assessment.

In addition to the risk assessments we are required to have in place (please refer to our risk assessment policy and health and safety policy for more information), we ensure we have risk assessments in place, regularly updated.

6. Monitoring arrangements

The application of this policy is monitored by the site manager and DoBS, among other things, visual checks of the school site and equipment, and checks of risk assessments. Copies of risk assessments and paperwork relating to any checks are kept in the site office.

This policy will be reviewed by Director of Business Service every 3 years. At every review, the policy will be shared with and approved by the governing body.

7. Links with other policies

This premises management policy is linked to:

- Health and safety policy
- Risk assessment policy

Prepared by: Miss L Flaherty & Mr N Williams

Approved by the Governing Body:

Signature: *Christina M. Burgess.*

Name: Christina Burgess, Chair of Governors

Date: 7th December 2020

To be reviewed in 1 year